

## COMMISSIONING RECORD

To validate the lifetime warranty, this Commissioning Record must be completed and left for the owner to fix it to, or adjacent to, the distribution board of the heating system.

Installer		
Date of commissioning	Customer name	
Name of installer	Phone	Mobile
Customer address		
Town/City	County	Postcode

**1. Description of heating system** (please select one):

eMat Pro    eCable    eFlex    eFoil

**2. The heating conductors are laid on:**

Tile backer board    Foil faced insulation    Timber base  
 Concrete base    Other

**3. Depth of heating conductors below the surface:** ..... mm

**4. The installed system is designed to provide:**

Primary heating    Secondary heating

**5. This system is controlled by:**

Programmable thermostat    Manual thermostat  
 Anticipatory controller    Other

**6. Rating of the protective device** (e.g. MCB/fuse): ..... amps

**7. Rating of RCD** (e.g. 30mA): ..... amps

**8. Voltage of system:** ..... V

(Please fill in all locations where underfloor heating is installed, e.g., Living Room, Kitchen, Bathroom etc.)

	Location ▶	▼	▼	▼	▼
Insulation resistance	Before covering				
	After floor covering				
Heating unit resistance	Before laying				
	Before covering				
	After floor covering				
Floor sensor resistance	Before laying				
	After floor covering				

**⚠ Caution**

- Flexible sheet heating units are installed in the floor
- Do not restrict the thermal emission of the heated floor, for example, thick mats or bean bags (maximum thermal resistance of 0.15m<sup>2</sup> K/W [1.5 tog]).
- Do not affix materials other than those recommended.
- Do not insert nails or screws.
- This underfloor system should not be turned on until the floor is completely dry and any screed/adhesive has fully cured. Once cured, the system should be turned on gradually over a 48 hour period.
- The underfloor heating units must be controlled with an approved thermostat and its control instructions.
- Should the heating unit become damaged the fault should be located and repaired with the approved repair kit.
- Installation must conform to current IEE BS 7671.

**eLine**

Edison House  
Edison Close  
Ransomes Europark  
Ipswich, Suffolk IP3 9GU  
United Kingdom

Tel: 01473 276677  
Fax: 01473 276678  
Email: [info@elementsunderfloorheating.co.uk](mailto:info@elementsunderfloorheating.co.uk)  
Web: [www.elementsunderfloorheating.co.uk](http://www.elementsunderfloorheating.co.uk)



**Label the heating units 1, 2, 3 and 4 then fill in the information below**

**1**

Q/F code .....

Total wattage .....

m<sup>2</sup> covered .....

**2**

Q/F code .....

Total wattage .....

m<sup>2</sup> covered .....

**3**

Q/F code .....

Total wattage .....

m<sup>2</sup> covered .....

**4**

Q/F code .....

Total wattage .....

m<sup>2</sup> covered .....

\*Refer to the label on the top of the mat box for Q/F code and total wattage

**In this box sketch a floor plan of the room and show the following:**

- Layout of the system indicating the heated area
- Position of junction boxes
- Position of floor sensor and thermostat

